TOWN OF CAZENOVIA • 7 ALBANY STREET • CAZENOVIA • NY 13035 • 315-655-9213

SOLID FUEL BURNING DEVICE PERMIT

Date:_____

Property Address:_____

Owner:_____

Address:_____

_____

Phone:_____

Type of Unit: ____Fireplace____Woodstove ____Coal Stove

____Pellet Stove ____Corn Stove ____Gas Insert

Room of use:_____

Floor Level: ____Basement ____1st Floor ____2nd Floor

Stove Manufacture:_____

Stove Model #:_____

Stove Serial #:_____

BTU Rating:_____

Stove Clearances: _____Left Side _____Right Side

_____Front _____Top _____Floor

Three (3) Screws in each pipe joint? ____Yes ____No ____N/A

Distance of pipe to combustibles:_____

Type and size of non-combustible wall protection with a one (1) inch

air space:_____

Type and size of non-combustible hearth:_____
(must extend at least 12" from each side and 18" from the ash door)

Type of pipe from appliance to chimney: _____

Chimney Type: ____Block/flue ____Brick/flue

____Double Wall ____Triple Wall

Are there **SMOKE DETECTORS** in every bedroom and on every level of the structure including basements and cellars?

Is there a **CARBON MONOXIDE** detector on the lowest sleeping level?

Installation: ____**APPROVED** ____**REJECTED**

Reason(s) for REJECTION:_____

_____

Stove Clearances



To prevent downdrafts and fire from sparks, chimney height must be at least 2 feet above any roof surface within 10 feet horizontally.



Prefabricated Chimney - Interior (Preferred) Installation



Prefabricated Chimney - Outside Installation



Chimney Connection



Per NFPA 211

FLOOR PROTECTION

* UNLESS STOVE IS ON A CONCRETE FLOOR, THIS FLOOR PROTECTION IS REQUIRED